

# CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI  
MAYOR

BOARD OF  
**BUILDING AND SAFETY  
COMMISSIONERS**

—  
VAN AMBATIELOS  
PRESIDENT

E. FELICIA BRANNON  
VICE-PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
GEORGE HOVAGUIMIAN  
JAVIER NUNEZ

DEPARTMENT OF  
**BUILDING AND SAFETY**  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

—  
RAYMOND S. CHAN, C.E., S.E.  
GENERAL MANAGER

FRANK BUSH  
EXECUTIVE OFFICER

Wej-It Fastening Systems  
Div. of Mechanical Plastics Corp.  
110 Richards Avenue  
Norwalk, CT 06854

Attn: David Garfield  
(203) 857-2200, ext. 707

RESERACH REPORT: RR 24939  
(CSI # 03 16 00)

BASED UPON ICC ES EVALUATION  
REPORT NO. ESR-2777

REEVALUATION DUE  
DATE: October 1, 2016  
Issued Date: January 1, 2015  
Code: 2014 LABC

**GENERAL APPROVAL** – Reevaluation-ANKR-Tite CCAT Wedge Anchor for Cracked and Uncracked Concrete.

## DETAILS

The above assemblies and/or products are approved when in compliance with the use, description, design, installation, conditions of approval and identification of Evaluation Report No. ESR-2777, reissued August 1, 2014, of the ICC Evaluation Service, LLC. The report, in its entirety, is attached and made part of this general approval.

The parts of Evaluation Report No. ESR-2777 marked by the asterisks have been deleted by the City of Los Angeles Building and Safety Department from this approval.

### The approval is subject to the following:

1. The 3/8 inch-diameter-anchors are not approved for seismic applications in accordance with Section 4.1.8.1 of the attached ICC ES report.
2. Special inspection in accordance with Section 1705.1.1 of the Los Angeles City Building Code by reinforced concrete, steel or reinforced masonry deputy inspector with controlled activity in drilled anchor bolts shall be provided.

RR 24939  
Page 1 of 2

Wej-It Fastening System

Re: Ankr-TITE CCAT Wedge Anchor for Cracked and Uncracked Concrete

3. The values shown in this report shall not be used in repair, retrofit and new construction of tilt-up wall or reinforced masonry wall anchorage (in tension) for the connection with the horizontal wood diaphragm.

## **DISCUSSION**

The report is in compliance with the 2014 Los Angeles City Building Code.

Special inspection is required when anchors are required to have a specified installation torque.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

---

QUAN NGHIEM, Chief  
Engineering Research Section  
201 N. Figueroa St., Room 880  
Los Angeles, CA 90012  
Phone- 213-202-9816  
Fax- 213-202-9943

EB  
RR24939/MSWord2010  
R12/28/14  
1901/1908

Attachments: ICC ES Evaluation Report No. ESR-2777 (9 Pages)